

TOWN OF ACTON  
PERMIT  
HAZARDOUS MATERIALS CONTROL PERMIT  
ARTICLE 25  
1985 ANNUAL TOWN MEETING

---

FILE NUMBER: 92-25

PROJECT LOCATION: 2 Eastern Road

APPLICANT: Doctor, Inc.  
Paul Murphy

DATE OF ISSUANCE: May 7, 1992

MAILING ADDRESS: 2 Eastern Road  
Acton, MA 01720

FEE: \$150.00 pd

*AM*

---

Pursuant to the authority of Chapter I - Hazardous Materials Control Bylaw of the Town of Acton's General Bylaws the Board of Health has considered your application and plans submitted therewith, and has determined that the materials to be stored within the scope of the said Bylaw. The Board of Health hereby orders that the following conditions are necessary and all storage must be performed in strict conformance herewith:

---

CONDITIONS:

1. Oil and waste must be removed by a qualified disposal service.
2. A yearly inspection of the underground storage tank must be done with a report to the Board of Health.
3. All M.S.D.'s must be made available for inspection by all workers.
4. Sufficient bags of cleanup material (i.e. speedy dry) must be available in the event of a spill of hazardous materials.
5. The containment buffer surrounding the drum be capable of holding 150 gallons.
6. The underground storage tank must be inspected once per year.
7. The underground storage tank must be at least 500 gallon capacity.